

CERTIFICATE OF CONSTANCY OF PERFORMANCE

Certificate No.
2821-CPR-0292

Issue date
30 Jul 2024

Issue No.
1



In compliance with the Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product and placed on the market under the name or trademark of

Manufacturer:

Codelocks Limited

Address:

Albury Way, Newbury, RG19 6HW
GB

Product:

P525 ML55 Mortice Lock

Places of production:

CODELOCKS CHINA CO LTD

Harmonized Standard

EN 12209: 2003/ EN 12209/AC: 2005

Head of Notified Body:

Erik Teubler

Issued by UL International (Netherlands) B.V., Notified Body 2821.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above referenced standard(s) under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods, nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Economic Operators:

Manufacturer: Codelocks Limited

Manufacturers Address: Albury Way, Newbury, RG19 6HW GB
Authorised Representative: Codelocks EU B.V.

Authorised Representative Address: Rigttersbleek-Aalten 4 (K1.01)
7521 RB Enschede
Nederland

Detailed information sheet:

Product Reference: P525 ML55
Type: Mortice Lock

Key Performance parameters: EN 12209: 2003/ EN 12209/AC: 2005 Classifications and Essential Characteristics.

Product	Essential Characteristic	Performance	Harmonized Standard
P525 ML55	Self-closing ability - closing force - return force on latch bolt	Grade 5 (200 kg, force 25 N) >2.5N	EN 12209:2003 EN 12209/AC:2005
	Durability of self-closing action Durability of latch action applied	X (200 000 test cycles) 120N side load on latch bolt	
	Ability to maintain door in closed position, and not contribute to the spread of fire	Grade 1*	

* Scope of use only applicable to timber based insulated doorsets for 30 and 60 minute periods. Must be fitted in conjunction with intumescent protection specified in manufacturer's fitting instructions.

Technical Documentation:

Ift report: No. 21-003378-PR03

FPA report: No. 105785 r1
No. 105786 r1

Limitations on the acceptance or use of the product(s):

Installation instructions	To be used in accordance with the supplier's installation instructions, and technical datasheet
Limitations	See Technical Data Sheet

Revision Table:

Version	Project Number	Date	Description
1.0	4790604810	30-07-2024	Initial

Terms and Conditions:

1. This certificate remains the property of UL International (NL) B.V, herein "UL NL", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL NL.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL NL.
5. This certificate is only valid for placing goods on the EU market.
6. The requirements for the economic operators stipulated in CHAPTER II, Article 4 of the Regulation (EU) 2019/1020 of the European Parliament and of the Council of 20 June 2019

END OF CERTIFICATE